

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1076:164 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Kidde-Fenwal, Inc., 400 Main Street, Ashland, MA 01721
Contact: Terrill Garland (508) 881-2000

DESIGN: Models ET70-24MCW and E70-24MCW multi-candela speaker/strobes. Units may be followed by suffixes to designate lens lettering and plate color. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 16-33 VDC
Flash rate: 60 flashes/min
Candela: Selectable 15cd, 30cd, 75cd or 110cd

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. For wall mount only.

MARKING: Listee's name, model number, electrical/candela rating and UL label.

APPROVAL: Listed as strobe speakers suitable for the hearing impaired when used in conjunction with separately listed electrically compatible fire alarm control units. For indoor use only.

If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition is required, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

XLF: 7125-0785:152

07-28-2002 BH



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JULY 28, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager